

System Name: Deer Meadow PWS ID: 1193030

2021 Report (2020 data)

BULK WATER DELIVERIES

Bulk Water Source	Dates of Water Delivery	Gallons Delivered	Reason for Delivery
No Bulk Water deliveries in 2020			

If a drinking water public notice, MCL, Monitoring/Reporting, or treatment technique violation has occurred, the following table should be used to explain the violation and health effects:

VIOLATIONS

VIOLATIONS	Date of violation	Explain violation	Length of violation	Action taken to resolve	Health Effects (Env-Dw 804-810)
No violations were reported in 2020	N/A				N/A

The Revised Total Coliform Rule requires an assessment or an investigation of the water system when certain conditions occur:

ASSESSMENTS

During the past year we were required to conduct ZERO Assessment(s)	Number of assessments required in the reporting year	Number of assessments completed in the reporting year	Number of corrective actions required	Number of corrective actions completed	Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.
				<i>If you completed all corrective actions you can remove the italicized statements in this table.</i>	

SIGNIFICANT DEFICIENCY

Significant deficiency description and date of sanitary survey	Source of <i>E.coli</i>	Date deficiency was addressed or corrected	Approved plan and timeframe for correction	Health Effects (Env-Dw 811.21)
<i>Inoperative treatment-An old chemical injection feed line was found to be connected to the system during the survey. Since there is not a plan to use this treatment, it was physically removed from the system to prevent any cross contamination.</i>	No E.Coli	Sanitary Survey 09/19/2017	Corrected	No health effects

*The value must be reported as whole number, see Env-Dw 811, Appendix B for conversions:

LEAD AND COPPER

Contaminant (Units)	Action Level	90 th percentile sample value *	Date	# of sites above AL	Violation Yes/No	Likely Source of Contamination	Health Effects of Contaminant
Copper (ppm)	1.3	0.012	09/05/19	ZERO	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
Lead (ppb)	15	0.000	09/05/19	ZERO	NO	Corrosion of household plumbing systems, erosion of natural deposits	(15 ppb in more than 5%) Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791). (above 15 ppb) Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

*If applicable report average and range and date sampled if prior to the reporting year. Level detected must be reported as whole number, see Env-Dw 811, Appendix B for conversions:

DETECTED WATER QUALITY RESULTS

Contaminant (Units)	Level Detected*	MCL	MCLG	Violation YES/NO	Likely Source of Contamination	Health Effects of Contaminant
Microbiological Contaminants: No Microbiological Contaminants						
Radioactive Contaminants						
Uranium (ug/L)	2 UG/L 07/19/17	30	0	NO	Erosion of natural deposits	Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity.
Combined Radium 226 + 228 (pCi/L)	ND 06/21/17	5	0	NO	Erosion of natural deposits	Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.
Inorganic Contaminants						
Arsenic (ppb)	0.0061 MGL 06/24/2020	10	0	NO	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes	(5 ppb through 10 ppb) While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. (above 10 ppb) Some people who drink water containing arsenic in excess of the MCL

					over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
Fluoride (ppm)	0.60 MGL 06/24/20	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.
Synthetic Organic Contaminants including Pesticides and Herbicides: No Synthetic Organic Contaminants including Pesticides and Herbicides					
Volatile Organic Contaminants: No Volatile Organic Contaminants					

*If applicable report average and range and date sampled if prior to the reporting year. Level detected must be reported as whole number, see Env-Dw 811, Appendix B for conversions:

PER- AND POLYFLUOROALKYL SUBSTANCES (PFAS) CONTAMINANTS

Contaminant (Units) NO PER- AND POLYFLUOROALKYL SUBSTANCES (PFAS) CONTAMINANTS			
--	--	--	--

SECONDARY CONTAMINANTS

Secondary MCLs (SMCL)	Level Detected	Date	Treatment technique (if any)	AL (Action Level), SMCL or AGQS (Ambient groundwater quality standard)	Specific contaminant criteria and reason for monitoring
Chloride (ppm)	ND	07/21/20	N/A	250	Wastewater, road salt, water softeners, corrosion
Fluoride (ppm)	0.60	07/21/20	N/A	2	<i>Add Health effects language from Env-Dw 806.11 or attach public notice to CCR</i>
Iron (ppm)	ND	07/21/20	N/A	0.3	Geological
Manganese (ppm)	0.0261	07/21/20	N/A	0.05	Geological
Nickel	ND	07/21/20	N/A	N/A	Geological; electroplating, battery production,ceramics
PH (ppm)	8.13	07/21/20	N/A	6.5-8.5	Precipitation and geology
Sodium (ppm)	13.4	07/21/20	N/A	100-250	We are required to regularly sample for sodium
Sulfate (ppm)	3.4	07/21/20	N/A	250	Naturally occurring
Zinc (ppm)	ND	07/21/20	N/A	5	Galvanized pipes